

Requirement of Estate (Electrical) to be procured through e-Tender-13/14-15 under CAT-D

Detail of requirement of ACs through rate contract:

Sr. No.	Type of AC	Capacity	Specifications	Qty.
1	Split AC	1.0T	5 Star, EER should be more than 3.48, sound level of ID unit should be less than 39db	03
2	Split AC	1.5T	5 Star, COP should be more than 3.67, sound level of ID unit should be less than 35db	02
3	Window AC	1.1T	5 Star, EER should be more than 11.30, COP should be more than 3.32, sound level should be less than 47db	58
4	Window AC	1.5T	5 Star, EER should be more than 11.35, COP should be more than 3.32, sound level should be less than 52db	12

Note:

1. The rate contract for procurement of ACs will be valid for a period of one year.
2. Quantity mentioned above may increase or decrease as per actual requirement.